

<b>End User</b>	<b>Port Facility in Andhra Pradesh</b>
<b>Project</b>	Fire Fighting pipeline –Internal & External Coating for Jetty 1 & 2

<b>Item</b>	<b>Pipe Dia</b>	<b>Specification</b>
Pipe Internal	3” -16” diameter	CORRO TECH PGF 500- 1mm
Pipe External		CLEAN TECH ZS PRIMER -1 x 75 micron CORRO GUARD HB MIO – 1 x 150 micron CLEAN TECH PU 150- Fire Red – 1 x 75 micron
Structures		CLEAN TECH ZS PRIMER -1 x 75 micron CORRO GUARD HB MIO – 1 x 150 micron CLEAN TECH PU 150- Grey– 1 x 75 micron

## Pipe Internal & External Coating.



## Pipe Internal & External Coating.

